

KARNES ELECTRIC COOPERATIVE, INC.

Main Office (830)780-3952

Pleasanton Office (830)569-5538

Date: 02-04-11

325 AMPERE 120-480 VOLT SERVICE UNDERGROUND SERVICE

COOPERATIVE FURNISHED, OWNED AND INSTALLED

- A. Pad Mount Transformer
- B. Pad
- C. Ground Rods
- D. 3" Conduit Stubbed out of Pad Approx. 3-4 Feet

MEMBER FURNISHED

- A. Metal Rack w/ **GROUNDING POINT** of **ATTACHMENT**
- B. 350 MCM Copper Minimum with Neutral Marked in White.
KEC does not allow paralleling of any other wire.
- C. 325 AMP Meter Base (KEC Approved).
- D. 400 AMP Disc Box with Main Breaker
- E. 3" Conduit

