

KARNES ELECTRIC COOPERATIVE, INC.

Karnes City Office (830)780-3952

Pleasanton Office (830)569-5538

Date: 10-31-17

200 AMPERE 120/240 VOLT SERVICE UNDERGROUND SERVICE

COOPERATIVE FURNISHED, OWNED AND INSTALLED

- A. Pad Mount Transformer
- B. Pad and Pedestal
- C. Ground Rods

MEMBER FURNISHED

- A. 200 Amp Disconnect with Main
- B. 2" Hub and 2" Metallic Nipple & Lock Nuts
- C. Bell Bushing Wire Protector in All Conduit Opening
- D. All Wire Shall Be Copper. Size: **Min. 2/0 Max. 4/0**

